



Łukasiewicz Research Network – Institute of Ceramics and Building Materials
31-983 Kraków, Cementowa 8 Str., Poland

CERAMIC AND CONCRETE DIVISION IN WARSAW

02-676 Warszawa
Postępu 9 Str., Poland
phone: +48 601 362 348

03-046 Warszawa
Kupiecka 4 Str., Poland
phone: +48 601 370 583

agnieszka.ducka@icimb.lukasiewicz.gov.pl
malgorzata.piotrowicz@icimb.lukasiewicz.gov.pl

RESEARCH LABORATORY

www.icimb.lukasiewicz.gov.pl



AB 054

TEST REPORT NO 61/1/P/LB/2022(EN)

SUBJECT OF TESTING: CERAMIC TILES

ORDERER: STARGRES Sp. z o.o.
ul. Ceramiczna 5
26-200 Końskie

DATE OF RECEIPT THE SAMPLES: 26.04.2022 r.

DATE OF TESTS: 19 – 20.05.2022

EXECUTOR: Technician Jacek Kamiński
M.Sc. Eng Marcin Pożarowszczyk

Number of copies: 1

Number of pages: 3

Warsaw, 23.05.2022

1. Subject of testing

Sample of the glazed dry-pressed ceramic tiles of the following type:

- CALACATTA 600 x 600 x 10 mm

Producer: STARGRES Sp. z o.o.
ul. Ceramiczna 5
26-200 Końskie

Number of sample: 2 pieces

Designation of sample: 61P/2022

The samples taken and delivered to the Research Laboratory by the Orderer.

2. Scope of tests and the place of their execution.

- determination of critical slip angle

Scope of tests has been established by the Customer.

Tests have been made in the Research Laboratory Research Group Ceramic, OCiB, ul. Kupiecka 4, 03-046 Warszawa.

3. Testing methods:

DIN 51130:2014–02 Testing of floor coverings. Determination of the anti-slip properties. Workrooms and fields of activities with slip danger, walking method. Ramp test.

4. Results of tests

4.1. Determination of critical slip angle.

According to DIN 51130:2014–02 Testing of floor coverings. Determination of the anti-slip properties. Workrooms and fields of activities with slip danger, walking method. Ramp test

Sample size: 0,5 m²

Critical slip angle	
Adjusted average overall acceptable angle α_{ges}	Anti-slip properties class
12,0	R 10


RESEARCH LABORATORY OF ŁUKASIEWICZ - ICI MB WP OCiB	TEST REPORT NO 61/1/P/LB/2022(EN)	page 3 / 3
--	--	------------

5.0. Statement.

5.1. Results of tests relate exclusively to tested objects.

5.2. Test report may be copied only as a whole, whereas for partial copying the consent of laboratory is required.

The person responsible for the report:


Agnieszka Ducka, M Sc

The person authorizing the report:

Z-ca Lidera Grupy Badawczej
Ceramika

mgr Agnieszka Ducka